

HIGH PRESSURE VALVE&FITTINGS. HIFLUX

# HYDROGEN PRODUCTS

HIFLUX produces and supplies hydrogen products for hydrogen industry.  
Special alloy material will be chosen for producing hydrogen products.

Hydrogen Station



# HIGH PRESSURE NEEDLE VALVE

Control and open/close the flow, Manual valve




## FEATURES

- 4 pattern Body Type. (Straight, Angle, 3Way/1on, 3Way/2on)
- Prevents galling due to the no-rotation stem.
- A valve using stainless steel 316 cold material for excellent corrosion resistant.
- Packing designed for reliable sealing.
- Metal to metal seating type to lengthen the life of the seat.
- 'Vee' or 'Regulating' stem for flow control and shut-off.

※ Parts have been changed from the high-pressure product to suitable materials for hydrogen.

## STRAIGHT TYPE

(Unit:mm)




| Catalog No.  | Stem | Pressure Rating | Port Type | Tube Size | Cv   | Orifice Size | Dimensions |      |    |    |    |    |     |      |     |       |      |      | Block Thickness |
|--------------|------|-----------------|-----------|-----------|------|--------------|------------|------|----|----|----|----|-----|------|-----|-------|------|------|-----------------|
|              |      |                 |           |           |      |              | A          | B    | C  | D  | D1 | E  | F   | G    | G1  | H     | M    | N    |                 |
| H-NV20VS04-S | Vee  | 20,000 psi      | H2004     | 1/4"      | 0.31 | 3.2          | 50         | 25   | 20 | 40 | 30 | 50 | 80  | 17   | 6.5 | 118.2 | 15.7 | 9.7  | 20              |
| H-NV20RS04-S | Reg  |                 |           |           |      |              | 50         | 25   | 20 | 40 | 30 | 50 | 80  | 17   | 6.5 | 117.5 | 15.7 | 9.7  | 20              |
| H-NV20VS06-S | Vee  |                 |           |           |      |              | 50         | 25   | 20 | 40 | 30 | 50 | 80  | 17   | 6.5 | 117.5 | 15.7 | 9.7  | 20              |
| H-NV20RS06-S | Reg  |                 |           |           |      |              | 50         | 25   | 20 | 40 | 30 | 50 | 80  | 17   | 6.5 | 117.5 | 15.7 | 9.7  | 20              |
| H-NV20VS09-S | Vee  |                 | H2009     | 9/16"     | 1.3  | 7.9          | 63         | 31.5 | 29 | 60 | 44 | 73 | 100 | 22   | 8   | 145   | 17.5 | 12.7 | 30              |
| H-NV20RS09-S | Reg  |                 |           |           |      |              | 63         | 31.5 | 29 | 60 | 44 | 73 | 100 | 22   | 8   | 145   | 17.5 | 12.7 | 30              |
| H-NV60VS04-S | Vee  | 60,000 psi      | H6004     | 1/4"      | 0.08 | 2            | 50         | 25   | 21 | 43 | 33 | 54 | 80  | 20.6 | 6.5 | 121.4 | 17   | 9.7  | 25              |
| H-NV60RS04-S | Reg  |                 |           |           |      |              | 50         | 25   | 21 | 43 | 33 | 54 | 80  | 20.6 | 6.5 | 121.4 | 17   | 9.7  | 25              |
| H-NV60VS06-S | Vee  |                 |           |           |      |              | 50         | 25   | 24 | 43 | 33 | 57 | 80  | 20.6 | 6.5 | 124.9 | 17   | 9.7  | 25              |
| H-NV60RS06-S | Reg  |                 |           |           |      |              | 50         | 25   | 24 | 43 | 33 | 57 | 80  | 20.6 | 6.5 | 124.9 | 17   | 9.7  | 25              |
| H-NV60VS09-S | Vee  |                 | H6009     | 9/16"     | 0.14 | 2            | 67         | 33.5 | 29 | 43 | 33 | 62 | 80  | 20.6 | 6.5 | 130   | 17   | 9.7  | 38              |
| H-NV60RS09-S | Reg  |                 |           |           |      |              | 67         | 33.5 | 29 | 43 | 33 | 62 | 80  | 20.6 | 6.5 | 130   | 17   | 9.7  | 38              |

G : The main top of the hole size  
G1 : Hole size of the main positive  
H : Height of the valve is fully closed

All dimensions may differ from the actual size for reference only.

## ANGLE TYPE

(Unit:mm)



| Catalog No.  | Stem | Pressure Rating | Port Type | Tube Size | Cv   | Orifice Size | Dimensions |      |      |    |      |     |      |     |        |      |      |    | Block Thickness |
|--------------|------|-----------------|-----------|-----------|------|--------------|------------|------|------|----|------|-----|------|-----|--------|------|------|----|-----------------|
|              |      |                 |           |           |      |              | A          | B    | C    | D  | E    | F   | G    | G1  | H      | M    | N    |    |                 |
| H-NV20VS04-A | Vee  | 20,000 psi      | H2004     | 1/4"      | 0.31 | 3.2          | 50         | 25   | 32   | 30 | 62   | 80  | 17   | 6.5 | 130.63 | 15.7 | 9.7  | 20 |                 |
| H-NV20RS04-A | Reg  |                 |           |           |      |              | 50         | 25   | 32   | 30 | 62   | 80  | 17   | 6.5 | 128.59 | 15.7 | 9.7  | 20 |                 |
| H-NV20VS06-A | Vee  |                 | H2006     | 3/8"      | 0.75 | 5.5          | 50         | 25   | 32   | 30 | 62   | 80  | 17   | 6.5 | 128.59 | 15.7 | 9.7  | 20 |                 |
| H-NV20RS06-A | Reg  |                 |           |           |      |              | 50         | 25   | 32   | 30 | 62   | 80  | 17   | 6.5 | 128.59 | 15.7 | 9.7  | 20 |                 |
| H-NV20VS09-A | Vee  |                 | H2009     | 9/16"     | 1.3  | 7.9          | 63         | 31.5 | 41.5 | 44 | 85.5 | 100 | 22   | 8   | 156.56 | 17.5 | 12.7 | 30 |                 |
| H-NV20RS09-A | Reg  |                 |           |           |      |              | 63         | 31.5 | 41.5 | 44 | 85.5 | 100 | 22   | 8   | 156.56 | 17.5 | 12.7 | 30 |                 |
| H-NV60VS04-A | Vee  | 60,000 psi      | H6004     | 1/4"      | 0.08 | 2            | 50         | 25   | 27.5 | 33 | 60.5 | 80  | 20.6 | 6.5 | 128.74 | 17   | 9.7  | 25 |                 |
| H-NV60RS04-A | Reg  |                 |           |           |      |              | 50         | 25   | 27.5 | 33 | 60.5 | 80  | 20.6 | 6.5 | 128.74 | 17   | 9.7  | 25 |                 |
| H-NV60VS06-A | Vee  |                 | H6006     | 3/8"      | 0.09 | 2            | 50         | 25   | 33.5 | 33 | 66.5 | 80  | 20.6 | 6.5 | 134.74 | 17   | 9.7  | 25 |                 |
| H-NV60RS06-A | Reg  |                 |           |           |      |              | 50         | 25   | 33.5 | 33 | 66.5 | 80  | 20.6 | 6.5 | 134.74 | 17   | 9.7  | 25 |                 |
| H-NV60VS09-A | Vee  |                 | H6009     | 9/16"     | 0.14 | 2            | 67         | 33.5 | 34   | 33 | 67   | 80  | 20.6 | 6.5 | 135.24 | 17   | 9.7  | 38 |                 |
| H-NV60RS09-A | Reg  |                 |           |           |      |              | 67         | 33.5 | 34   | 33 | 67   | 80  | 20.6 | 6.5 | 135.24 | 17   | 9.7  | 38 |                 |

G : The main top of the hole size  
G1 : Hole size of the main positive  
H : Height of the valve is fully closed

All dimensions may differ from the actual size for reference only.


# HIGH PRESSURE NEEDLE VALVE



Control and open/close the flow, Manual valve



## EXPLODED VIEW & CONNECTION COMPONENTS


- ① Valve Handle
- ② Stem
- ③ Stem Locking
- ④ Valve Fixed Hole
- ⑤ Packing
- ⑥ Body Block
- ⑦ Connections



|                                                                                     |                                     |
|-------------------------------------------------------------------------------------|-------------------------------------|
|  | Medium Pressure<br>20,000psi        |
|  | High Pressure<br>30,000 ~ 60,000psi |

## 3WAY/10N PRESSURE TYPE

(Unit:mm)




| Catalog No.  | Stem | Pressure Rating | Port Type | Tube Size | Cv   | Orifice Size | Dimensions |      |      |    |      |     |      |     |        |      |      | Block Thickness |
|--------------|------|-----------------|-----------|-----------|------|--------------|------------|------|------|----|------|-----|------|-----|--------|------|------|-----------------|
|              |      |                 |           |           |      |              | A          | B    | C    | D  | E    | F   | G    | G1  | H      | M    | N    |                 |
| H-NV20VS04-O | Vee  | 20,000 psi      | H2004     | 1/4"      | 0.31 | 3.2          | 50         | 25   | 32   | 30 | 62   | 80  | 17   | 6.5 | 130.63 | 15.7 | 9.7  | 20              |
| H-NV20RS04-O | Reg  |                 |           | 1/4"      | 0.31 | 3.2          | 50         | 25   | 32   | 30 | 62   | 80  | 17   | 6.5 | 130.63 | 15.7 | 9.7  | 20              |
| H-NV20VS06-O | Vee  |                 |           | 3/8"      | 0.75 | 5.5          | 50         | 25   | 32   | 30 | 62   | 80  | 17   | 6.5 | 129.49 | 15.7 | 9.7  | 20              |
| H-NV20RS06-O | Reg  |                 |           | 3/8"      | 0.75 | 5.5          | 50         | 25   | 32   | 30 | 62   | 80  | 17   | 6.5 | 129.49 | 15.7 | 9.7  | 20              |
| H-NV20VS09-O | Vee  |                 | H2009     | 9/16"     | 1.3  | 7.9          | 63         | 31.5 | 42   | 44 | 86   | 100 | 22   | 8   | 157.49 | 17.5 | 12.7 | 30              |
| H-NV20RS09-O | Reg  |                 |           | 9/16"     | 1.3  | 7.9          | 63         | 31.5 | 42   | 44 | 86   | 100 | 22   | 8   | 157.49 | 17.5 | 12.7 | 30              |
| H-NV60VS04-O | Vee  | 60,000 psi      | H6004     | 1/4"      | 0.08 | 2            | 50         | 25   | 27.5 | 33 | 60.5 | 80  | 20.6 | 6.5 | 128.74 | 17   | 9.7  | 25              |
| H-NV60RS04-O | Reg  |                 |           | 1/4"      | 0.08 | 2            | 50         | 25   | 27.5 | 33 | 60.5 | 80  | 20.6 | 6.5 | 128.74 | 17   | 9.7  | 25              |
| H-NV60VS06-O | Vee  |                 | H6006     | 3/8"      | 0.09 | 2            | 50         | 25   | 34   | 33 | 67   | 80  | 20.6 | 6.5 | 135.24 | 17   | 9.7  | 25              |
| H-NV60RS06-O | Reg  |                 |           | 3/8"      | 0.09 | 2            | 50         | 25   | 34   | 33 | 67   | 80  | 20.6 | 6.5 | 135.24 | 17   | 9.7  | 25              |
| H-NV60VS09-O | Vee  |                 | H6009     | 9/16"     | 0.14 | 2            | 67         | 33.5 | 38.5 | 33 | 71.5 | 80  | 20.6 | 6.5 | 139.74 | 17   | 9.7  | 38              |
| H-NV60RS09-O | Reg  |                 |           | 9/16"     | 0.14 | 2            | 67         | 33.5 | 38.5 | 33 | 71.5 | 80  | 20.6 | 6.5 | 139.74 | 17   | 9.7  | 38              |

G : The main top of the hole size  
G1 : Hole size of the main positive  
H : Height of the valve is fully closed

All dimensions may differ from the actual size for reference only.

## 3WAY/20N PRESSURE TYPE

(Unit:mm)



| Catalog No.  | Stem | Pressure Rating | Port Type | Tube Size | Cv   | Orifice Size | Dimensions |      |      |    |    |      |     |      |     |        |      | Block Thickness |    |
|--------------|------|-----------------|-----------|-----------|------|--------------|------------|------|------|----|----|------|-----|------|-----|--------|------|-----------------|----|
|              |      |                 |           |           |      |              | A          | B    | C    | D  | D1 | E    | F   | G    | G1  | H      | M    |                 | N  |
| H-NV20VS04-T | Vee  | 20,000 psi      | H2004     | 1/4"      | 0.31 | 3.2          | 50         | 25   | 36.5 | 40 | 30 | 66.5 | 80  | 17   | 6.5 | 135.13 | 15.7 | 9.7             | 20 |
| H-NV20RS04-T | Reg  |                 |           |           |      |              |            |      |      |    |    |      |     |      |     |        |      |                 |    |
| H-NV20VS06-T | Vee  |                 | H2006     | 3/8"      | 0.75 | 5.5          | 50         | 25   | 36.5 | 40 | 30 | 66.5 | 80  | 17   | 6.5 | 133.99 | 15.7 | 9.7             | 20 |
| H-NV20RS06-T | Reg  |                 |           |           |      |              |            |      |      |    |    |      |     |      |     |        |      |                 |    |
| H-NV20VS09-T | Vee  |                 | H2009     | 9/16"     | 1.3  | 7.9          | 63         | 31.5 | 48   | 60 | 44 | 92   | 100 | 22   | 8   | 163.99 | 17.5 | 12.7            | 30 |
| H-NV20RS09-T | Reg  |                 |           |           |      |              |            |      |      |    |    |      |     |      |     |        |      |                 |    |
| H-NV60VS04-T | Vee  | 60,000 psi      | H6004     | 1/4"      | 0.08 | 2            | 50         | 25   | 27.5 | 43 | 33 | 60.5 | 80  | 20.6 | 6.5 | 128.74 | 17   | 9.7             | 25 |
| H-NV60RS04-T | Reg  |                 |           |           |      |              |            |      |      |    |    |      |     |      |     |        |      |                 |    |
| H-NV60VS06-T | Vee  |                 | H6006     | 3/8"      | 0.09 | 2            | 50         | 25   | 38.5 | 43 | 33 | 71.5 | 80  | 20.6 | 6.5 | 139.74 | 17   | 9.7             | 25 |
| H-NV60RS06-T | Reg  |                 |           |           |      |              |            |      |      |    |    |      |     |      |     |        |      |                 |    |
| H-NV60VS09-T | Vee  |                 | H6009     | 9/16"     | 0.14 | 2            | 67         | 33.5 | 44   | 43 | 33 | 77   | 80  | 20.6 | 6.5 | 145.24 | 17   | 9.7             | 38 |
| H-NV60RS09-T | Reg  |                 |           |           |      |              |            |      |      |    |    |      |     |      |     |        |      |                 |    |

G : The main top of the hole size  
G1 : Hole size of the main positive  
H : Height of the valve is fully closed

All dimensions may differ from the actual size for reference only.

# NEEDLE VALVE FOR HYDROGEN FUEL STATION

Manual Valves for hydrogen fuel stations with controlled flow or opening and closing the flow of fluid or gas.

KOLAS test passed

※ Test reports are enclosed 13p


## FEATURES

- Prevents galling due to the no-rotation stem.
- Packing designed for reliable sealing.
- Metal to metal sealing type to lengthen the life of the seat.
- Excellent corrosion resistance.
- Straight Body Type.

## MATERIAL

- Body : STS 316CW
- Stem : STR 660
- O-ring : EPDM
- Packing : TEFLON

## STRAIGHT TYPE



(Unit:mm)




| Catalog No.    | Pressure Rating    | Port Type | Tube Size | Orifice Size | Dimensions |      |    |      |      |      |     |        |       |        |      |      |    | Block Thickness |
|----------------|--------------------|-----------|-----------|--------------|------------|------|----|------|------|------|-----|--------|-------|--------|------|------|----|-----------------|
|                |                    |           |           |              | A          | B    | C  | D    | D1   | E    | F   | G(HEX) | G1(Ø) | H      | M    | N    |    |                 |
| HRS-NV20VS04-S | H70 Pressure Class | H2004     | 1/4"      | 3.2          | 50         | 25   | 20 | 44.5 | 34.5 | 54.5 | 80  | 17     | 6.5   | 122.15 | 15.7 | 9.7  | 20 |                 |
| HRS-NV20VS06-S |                    | H2006     | 3/8"      | 5.5          | 50         | 25   | 20 | 44.5 | 34.5 | 54.5 | 80  | 17     | 6.5   | 122.15 | 15.7 | 9.7  | 20 |                 |
| HRS-NV20VS09-S |                    | H2009     | 9/16"     | 7.9          | 63         | 31.5 | 29 | 63   | 47   | 76   | 100 | 22     | 8     | 150.7  | 17.5 | 12.7 | 30 |                 |
| HRS-NV20VS12-S |                    | H2012     | 3/4"      | 11           | 76         | 38   | 38 | 81   | 62   | 100  | 253 | 30     | 10    | 177.63 | 23   | 15.8 | 35 |                 |

G : The main top of the hole size  
 G1 : Hole size of the main positive  
 H : Height of the valve is fully closed

All dimensions may differ from the actual size for reference only.

## OPTION

- Lets you select a handle color.  
 (Black is the default color.)
- Black, Blue, Red (3 Colors)



# HYDROGEN CHECK VALVE

Gas or liquid prevents flowing backward






## FEATURES

- Check valve of U-packing type
- Excellent corrosion resistant.
- A valve using stainless steel 316 cold material for preventing reverse flow.
- A valve that facilitates one-directional movement by blocking the reverse flow of gas or liquid.
- Cone and thread connection to prevent gas or liquid leaking.

※ Parts have been changed from the high-pressure product to suitable materials for hydrogen.

## HYDROGEN CHECK VALVE



(Unit:mm)

| Catalog No.        | Pressure Rating          | Port Type | Tube Size | Orifice Size | Dimensions |      |
|--------------------|--------------------------|-----------|-----------|--------------|------------|------|
|                    |                          |           |           |              | A          | HEX  |
| HRS-CV20US04-00-00 | H70<br>Pressure<br>Class | H2004     | 1/4"      | 2.8          | 77.9       | 25.4 |
| HRS-CV20US06-00-00 |                          | H2006     | 3/8"      | 5.2          | 81.06      | 25.4 |
| HRS-CV20US09-00-00 |                          | H2009     | 9/16"     | 7.9          | 106.2      | 36   |

All dimensions may differ from the actual size for reference only.

# HIGH PRESSURE FITTING


Fitting & accessory used simple structure design and wear resistant material for high pressure connection



## FEATURES

- 3 patterns body types. (Elbow, Tee, Cross Type)
- A valve using stainless steel 316 cold material for excellent corrosion resistant.
- Cone and thread connection is strong in relation to water.
- leaks even when using gas and liquid.
- The operation temperature ranges from -423°F (-252°C) to 1200°F (649°C) Fitting is used for connecting.
- Tubes at high pressure and has a high-flow property and diverse sized orifice according to pressure.

## ELBOW TYPE




(Unit:mm)

| Catalog No. | Pressure Rating | Port Type | Tube Size | Orifice Size | Dimensions |      |       |        |      |      | Block Thickness |
|-------------|-----------------|-----------|-----------|--------------|------------|------|-------|--------|------|------|-----------------|
|             |                 |           |           |              | A          | B    | C     | D(HEX) | E    | F    |                 |
| FT20ES04    | 20,000 psi      | H2004     | 1/4"      | 2.8          | 28.5       | 28.5 | 13.8  | 12     | 19   | 19   | 16              |
| FT20ES06    |                 | H2006     | 3/8"      | 5.2          | 35         | 35   | 14.2  | 16     | 25   | 25   | 20              |
| FT20ES09    |                 | H2009     | 9/16"     | 7.9          | 45         | 45   | 19.3  | 22     | 31.5 | 31.5 | 25              |
| FT20ES12    |                 | H2012     | 3/4"      | 13           | 57         | 57   | 19.3  | 28     | 38   | 38   | 35              |
| FT20ES16    |                 | H2016     | 1"        | 17.5         | 76         | 76   | 21.7  | 35     | 52.5 | 52.5 | 45              |
| FT60ES04    | 60,000 psi      | H6004     | 1/4"      | 2.4          | 35         | 35   | 12.83 | 16     | 22.5 | 22.5 | 25              |
| FT60ES06    |                 | H6006     | 3/8"      | 3.2          | 38         | 45   | 18.6  | 20     | 25   | 31.5 | 25              |
| FT60ES09    |                 | H6009     | 9/16"     | 4.8          | 47.5       | 67   | 21.66 | 30     | 28.5 | 48   | 38              |

All dimensions may differ from the actual size for reference only.

## TEE TYPE




(Unit:mm)

| Catalog No. | Pressure Rating | Port Type | Tube Size | Orifice Size | Dimensions |     |       |        |      |       | Block Thickness |
|-------------|-----------------|-----------|-----------|--------------|------------|-----|-------|--------|------|-------|-----------------|
|             |                 |           |           |              | A          | B   | C     | D(HEX) | E    | F     |                 |
| FT20TS04    | 20,000 psi      | H2004     | 1/4"      | 2.8          | 28.5       | 38  | 13.8  | 12     | 19   | 19    | 16              |
| FT20TS06    |                 | H2006     | 3/8"      | 5.2          | 35         | 50  | 14.2  | 16     | 25   | 25    | 20              |
| FT20TS09    |                 | H2009     | 9/16"     | 7.9          | 45         | 63  | 19.3  | 22     | 31.5 | 31.5  | 25              |
| FT20TS12    |                 | H2012     | 3/4"      | 13           | 57         | 76  | 19.3  | 28     | 38   | 38    | 35              |
| FT20TS16    |                 | H2016     | 1"        | 17.5         | 76         | 105 | 21.7  | 35     | 52.5 | 52.5  | 45              |
| FT60TS04    | 60,000 psi      | H6004     | 1/4"      | 2.4          | 35         | 50  | 12.83 | 16     | 22.5 | 25    | 25              |
| FT60TS06    |                 | H6006     | 3/8"      | 3.2          | 40         | 50  | 18.6  | 20     | 27   | 25    | 25              |
| FT60TS09    |                 | H6009     | 9/16"     | 4.8          | 54         | 67  | 21.66 | 30     | 35   | 33.25 | 38              |

All dimensions may differ from the actual size for reference only.

## CROSS TYPE



(Unit:mm)

| Catalog No. | Pressure Rating | Port Type | Tube Size | Orifice Size | Dimensions |     |       |        |       |      | Block Thickness |
|-------------|-----------------|-----------|-----------|--------------|------------|-----|-------|--------|-------|------|-----------------|
|             |                 |           |           |              | A          | B   | C     | D(HEX) | E     | F    |                 |
| FT20CS04    | 20,000 psi      | H2004     | 1/4"      | 2.8          | 38         | 38  | 13.8  | 12     | 19    | 19   | 16              |
| FT20CS06    |                 | H2006     | 3/8"      | 5.2          | 50         | 50  | 14.2  | 16     | 25    | 25   | 20              |
| FT20CS09    |                 | H2009     | 9/16"     | 7.9          | 63         | 63  | 19.3  | 22     | 31.5  | 31.5 | 25              |
| FT20CS12    |                 | H2012     | 3/4"      | 13           | 76         | 76  | 19.3  | 28     | 38    | 38   | 35              |
| FT20CS16    |                 | H2016     | 1"        | 17.5         | 105        | 105 | 21.7  | 35     | 52.5  | 52.5 | 45              |
| FT60CS04    | 60,000 psi      | H6004     | 1/4"      | 2.4          | 38         | 50  | 12.83 | 16     | 19    | 25   | 25              |
| FT60CS06    |                 | H6006     | 3/8"      | 3.2          | 50         | 54  | 18.6  | 20     | 25    | 27   | 25              |
| FT60CS09    |                 | H6009     | 9/16"     | 4.8          | 67         | 70  | 21.66 | 30     | 33.25 | 35   | 38              |

All dimensions may differ from the actual size for reference only.

# HIGH PRESSURE TUBING

Using stainless steel 316 cold material for excellent corrosion resistant



## FEATURES

- Tube is sold in a 6000mm (6M) unit.
- Using stainless steel 316 cold material for excellent corrosion resistant.
- If you want a water pressure test conducted, we can conduct the test based on a rule under pressure to be used.
- Suitable for chemical, oil refining, research, oil and gas companies, this product is used for various pressures.
- Customizable with other materials for a variety of fluids and gases.

## TUBE

(Unit:mm)

| Catalog No. | Pressure Rating | Port Type | Tube Size | Dimensions       |                 | Thickness | Flow Area(mm <sup>2</sup> ) | Working pressure psi (bar) |              |               |               |               |
|-------------|-----------------|-----------|-----------|------------------|-----------------|-----------|-----------------------------|----------------------------|--------------|---------------|---------------|---------------|
|             |                 |           |           | Outside Diameter | Inside Diameter |           |                             | -198~37.8℃<br>-325~100°F   | 93℃<br>200°F | 204℃<br>400°F | 316℃<br>600°F | 427℃<br>800°F |
| T20S04      | 20,000 psi      | H2004     | 1/4"      | 6.35             | 2.77            | 1.78      | 5.81                        | 1378.93                    | 1378.93      | 1327.22       | 1244.48       | 1158.30       |
| T20S06      |                 | H2006     | 3/8"      | 9.53             | 5.16            | 2.18      | 20.65                       | 1378.93                    | 1378.93      | 1327.22       | 1244.48       | 1158.30       |
| T20S09      |                 | H2009     | 9/16"     | 14.29            | 7.92            | 3.18      | 49.03                       | 1378.93                    | 1378.93      | 1327.22       | 1244.48       | 1158.30       |
| T20S12      |                 | H2012     | 3/4"      | 19.05            | 11.13           | 3.96      | 97.42                       | 1378.93                    | 1378.93      | 1327.22       | 1244.48       | 1158.30       |
| T20S16      |                 | H2016     | 1"        | 25.4             | 14.27           | 5.56      | 160.0                       | 1378.93                    | 1378.93      | 1327.22       | 1244.48       | 1158.30       |
| T60S04      | 60,000 psi      | H6004     | 1/4"      | 6.35             | 2.11            | 2.11      | 3.23                        | 4136.79                    | 4136.79      | 3981.66       | 3740.35       | 3495.59       |
| T60S06      |                 | H6006     | 3/8"      | 9.53             | 3.18            | 3.18      | 7.74                        | 4136.79                    | 4136.79      | 3981.66       | 3740.35       | 3495.59       |
| T60S09      |                 | H6009     | 9/16"     | 14.29            | 4.78            | 4.75      | 18.06                       | 4136.79                    | 4136.79      | 3981.66       | 3740.35       | 3495.59       |

All dimensions may differ from the actual size for reference only.

## NIPPLE

(Unit:mm)

| Catalog No. | Pressure Rating | Port Type | Tube Size | Dimensions       |                 | Thickness | Minimum Length | Flow Area(mm <sup>2</sup> ) | Working Pressure psi (bar) |              |               |               |               |
|-------------|-----------------|-----------|-----------|------------------|-----------------|-----------|----------------|-----------------------------|----------------------------|--------------|---------------|---------------|---------------|
|             |                 |           |           | Outside Diameter | Inside Diameter |           |                |                             | -198~37.8℃<br>-325~100°F   | 93℃<br>200°F | 204℃<br>400°F | 316℃<br>600°F | 427℃<br>800°F |
| N20S04      | 20,000 psi      | H2004     | 1/4"      | 6.35             | 2.77            | 1.78      | 70             | 5.81                        | 1378.93                    | 1378.93      | 1327.22       | 1244.48       | 1158.30       |
| N20S06      |                 | H2006     | 3/8"      | 9.53             | 5.16            | 2.18      | 88             | 20.65                       | 1378.93                    | 1378.93      | 1327.22       | 1244.48       | 1158.30       |
| N20S09      |                 | H2009     | 9/16"     | 14.29            | 7.92            | 3.18      | 110            | 49.03                       | 1378.93                    | 1378.93      | 1327.22       | 1244.48       | 1158.30       |
| N20S12      |                 | H2012     | 3/4"      | 19.05            | 11.13           | 3.96      | 118            | 97.42                       | 1378.93                    | 1378.93      | 1327.22       | 1244.48       | 1158.30       |
| N20S16      |                 | H2016     | 1"        | 25.4             | 14.27           | 5.56      | 168            | 160.0                       | 1378.93                    | 1378.93      | 1327.22       | 1244.48       | 1158.30       |
| N60S04      | 60,000 psi      | H6004     | 1/4"      | 6.35             | 2.11            | 2.11      | 74             | 3.23                        | 4136.79                    | 4136.79      | 3981.66       | 3740.35       | 3495.59       |
| N60S06      |                 | H6006     | 3/8"      | 9.53             | 3.18            | 3.18      | 104            | 7.74                        | 4136.79                    | 4136.79      | 3981.66       | 3740.35       | 3495.59       |
| N60S09      |                 | H6009     | 9/16"     | 14.29            | 4.78            | 4.75      | 135            | 18.06                       | 4136.79                    | 4136.79      | 3981.66       | 3740.35       | 3495.59       |

All dimensions may differ from the actual size for reference only.




# HIGH PRESSURE NEEDLE VALVE

Control and open/close the flow, Manual valve

## KOLAS CERTIFICATION

KOLAS Hydrogen charging station valve certificate

### Test Report

|                                                                                                                                                                                                                                                                                      |                |                                                                      |                                                                                   |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------|----------------------------------------------------------------------|-----------------------------------------------------------------------------------|
| Korea Gas Safety Corporation<br>Energy Safety Empirical Research Center<br>160-51, Songhakjcheon-ro, Juchon-myeon, Yeongwol-gun,<br>Gangwon-do, Republic of Korea<br>Tel : 033-834-2500 Fax : 033-750-1946                                                                           |                | Certificate No. :<br>KGSE-인공-22-161<br>Page( 1 / 1 ) ( 2 / 2 ) Pages |  |
| <b>1. Client</b><br><input type="radio"/> Name : Hiflux Corporation<br><input type="radio"/> Address : 361-23, Gapcheon-ro, Yuseong-gu, Daejeon, Republic of Korea                                                                                                                   |                |                                                                      |                                                                                   |
| <b>2. Test sample/Product name :</b>                                                                                                                                                                                                                                                 |                |                                                                      |                                                                                   |
| Type                                                                                                                                                                                                                                                                                 | Model No.      | Size                                                                 | Sample No. Hydrogen service level <sup>2)</sup>                                   |
| Manual Valve                                                                                                                                                                                                                                                                         | HBS-NV20V504-S | 6.35 mm <sup>1)</sup>                                                | #1 II70                                                                           |
| 1) 1/16 inch is equivalent to 6.35 mm<br>2) Maximum allowable working pressure specified by manufacture : 96.3 MPa                                                                                                                                                                   |                |                                                                      |                                                                                   |
| <b>3. Test period :</b> 2022.01.24. ~ 2022.04.26.                                                                                                                                                                                                                                    |                |                                                                      |                                                                                   |
| <b>4. Location of Test :</b> <input checked="" type="checkbox"/> Permanent Test Lab <input type="checkbox"/> On Site Testing<br>(Address : 1467-51, Songhakjcheon-ro, Juchon-myeon, Yeongwol-gun,<br>Gangwon-do, Republic of Korea)                                                  |                |                                                                      |                                                                                   |
| <b>5. Test method used :</b> KS B ISO 19880-3 : 2018<br>10.2.2 Hydrogen gas pressure cycle test, 10.2.3 External leakage test,<br>10.2.4 Internal leakage test, 10.2.5 Worst case fault pressure test,<br>10.2.6 Proof pressure test, 10.2.7 Hydrostatic strength test               |                |                                                                      |                                                                                   |
| <b>6. Test Results :</b> (See attached sheets)<br>This test report is specific to a sample item provided by client.<br>* marked test result is beyond the range of the accreditation of testing institution<br>Related to KS Q ISO/IEC 17025 and KOLAS Accreditation simultaneously. |                |                                                                      |                                                                                   |
| Affirmation Tested by :  Technical Manager<br>Name : Byeongil Jeong (Signature) Name : Donghoon Lee (Signature)                                                                                     |                |                                                                      |                                                                                   |
| The above test report is the accredited test results by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA.                                                                                                                                                            |                |                                                                      |                                                                                   |
| September. 30. 2022                                                                                                                                                                                                                                                                  |                |                                                                      |                                                                                   |
| KOLAS(Korea Laboratory Accreditation Scheme) Accreditation                                                                                                                                                                                                                           |                |                                                                      |                                                                                   |
| KOREA GAS SAGETY CORPORATION 한국가스안전공사<br>ENERGY SAFETY EMPIRICAL RESEARCH CENTER 에너지안전시험연구원                                                                                                                                                                                          |                |                                                                      |                                                                                   |
| If you need to verify authenticity test, please contact *82(33-834-2500)Quality Manager                                                                                                                                                                                              |                |                                                                      |                                                                                   |
| KGSE-TP-16-02(06)                                                                                                                                                                                                                                                                    |                |                                                                      |                                                                                   |

한국가스안전공사

### Test Results


|                                                                                                                                                                                                            |                                                |                                                                      |                                                                                     |             |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|----------------------------------------------------------------------|-------------------------------------------------------------------------------------|-------------|
| Korea Gas Safety Corporation<br>Energy Safety Empirical Research Center<br>160-51, Songhakjcheon-ro, Juchon-myeon, Yeongwol-gun,<br>Gangwon-do, Republic of Korea<br>Tel : 033-834-2500 Fax : 033-750-1946 |                                                | Certificate No. :<br>KGSE-인공-22-161<br>Page( 2 / 1 ) ( 2 / 2 ) Pages |  |             |
| <b>0 Test results</b>                                                                                                                                                                                      |                                                |                                                                      |                                                                                     |             |
| Number                                                                                                                                                                                                     | Test items                                     | Unit                                                                 | Result                                                                              | Notes       |
| 1                                                                                                                                                                                                          | Hydrogen gas pressure cycle test <sup>1)</sup> | Room test temperature                                                | Cycle                                                                               | 100 000     |
|                                                                                                                                                                                                            |                                                | Minimum test temperature                                             | Cycle                                                                               | 1 000       |
|                                                                                                                                                                                                            |                                                | Maximum test temperature                                             | Cycle                                                                               | 1 000       |
| 2                                                                                                                                                                                                          | External leakage test <sup>2)</sup>            | High pressure                                                        | —                                                                                   | Bubble-free |
| 3                                                                                                                                                                                                          | Internal leakage test <sup>3)</sup>            | Low pressure                                                         | —                                                                                   | Bubble-free |
|                                                                                                                                                                                                            |                                                | Worst case fault pressure test <sup>4)</sup>                         | Cycle                                                                               | 10          |
| 4                                                                                                                                                                                                          | Leakage                                        | External leakage test <sup>5)</sup>                                  | —                                                                                   | Bubble-free |
|                                                                                                                                                                                                            |                                                | Internal leakage test <sup>6)</sup>                                  | —                                                                                   | Bubble-free |
| 5                                                                                                                                                                                                          | Proof pressure test <sup>7)</sup>              | Low pressure                                                         | —                                                                                   | No leakage  |
| 6                                                                                                                                                                                                          | Hydrostatic strength test <sup>8)</sup>        | —                                                                    | —                                                                                   | No leakage  |

1) Hydrogen gas pressure cycle test : 100 000 cycles shall be completed at room temperature, with additional 1 000 cycles at an ambient temperature of -40 °C (+3 °C, -3 °C) and 1 000 cycles at an ambient temperature of 85 °C (+3 °C, -3 °C).  
- Pressure : Less than 5 % of the component pressure rating and the component pressure rating (+3 %, -0 %)  
2) External leakage test :  
- Pressure : At least 100 % of the component pressure rating  
- Temperature : -40 °C (+3 °C, -3 °C) and 85 °C (+3 °C, -3 °C)  
3) Internal leakage test :  
- Pressure : The pressure for the high pressure test is at least 100 % of the component pressure rating, and the pressure for the low pressure test is 25 % or less of the component pressure rating.  
- Temperature : -40 °C (+3 °C, -3 °C) and 85 °C (+3 °C, -3 °C)  
4) Worst case fault pressure test : Cycling is completed between 5 % or less of 110 % of the component pressure rating and at least 110 % of the component pressure rating (+3 %, -0 %)  
5) Proof pressure test : The pressure is slowly increased to 150 % of the component pressure rating and maintain that pressure for 10 min  
6) Hydrostatic strength test : pressure is increased to 2.4 times of the component pressure rating  
- End -

KGSE-TP-16-02(06)

한국가스안전공사

### Test Report

|                                                                                                                                                                                                                                                                                      |                |                                                                      |                                                                                     |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------|----------------------------------------------------------------------|-------------------------------------------------------------------------------------|
| Korea Gas Safety Corporation<br>Energy Safety Empirical Research Center<br>160-51, Songhakjcheon-ro, Juchon-myeon, Yeongwol-gun,<br>Gangwon-do, Republic of Korea<br>Tel : 033-834-2500 Fax : 033-750-1946                                                                           |                | Certificate No. :<br>KGSE-인공-22-162<br>Page( 1 / 1 ) ( 2 / 2 ) Pages |  |
| <b>1. Client</b><br><input type="radio"/> Name : Hiflux Corporation<br><input type="radio"/> Address : 361-23, Gapcheon-ro, Yuseong-gu, Daejeon, Republic of Korea                                                                                                                   |                |                                                                      |                                                                                     |
| <b>2. Test sample/Product name :</b>                                                                                                                                                                                                                                                 |                |                                                                      |                                                                                     |
| Type                                                                                                                                                                                                                                                                                 | Model No.      | Size                                                                 | Sample No. Hydrogen service level <sup>2)</sup>                                     |
| Manual Valve                                                                                                                                                                                                                                                                         | HBS-NV20V509-S | 14.29 mm <sup>1)</sup>                                               | #2 II70                                                                             |
| 1) 5/16 inch is equivalent to 14.29 mm<br>2) Maximum allowable working pressure specified by manufacture : 96.3 MPa                                                                                                                                                                  |                |                                                                      |                                                                                     |
| <b>3. Test period :</b> 2022.01.24. ~ 2022.04.26.                                                                                                                                                                                                                                    |                |                                                                      |                                                                                     |
| <b>4. Location of Test :</b> <input checked="" type="checkbox"/> Permanent Test Lab <input type="checkbox"/> On Site Testing<br>(Address : 1467-51, Songhakjcheon-ro, Juchon-myeon, Yeongwol-gun,<br>Gangwon-do, Republic of Korea)                                                  |                |                                                                      |                                                                                     |
| <b>5. Test method used :</b> KS B ISO 19880-3 : 2018<br>10.2.2 Hydrogen gas pressure cycle test, 10.2.3 External leakage test,<br>10.2.4 Internal leakage test, 10.2.5 Worst case fault pressure test,<br>10.2.6 Proof pressure test, 10.2.7 Hydrostatic strength test               |                |                                                                      |                                                                                     |
| <b>6. Test Results :</b> (See attached sheets)<br>This test report is specific to a sample item provided by client.<br>* marked test result is beyond the range of the accreditation of testing institution<br>Related to KS Q ISO/IEC 17025 and KOLAS Accreditation simultaneously. |                |                                                                      |                                                                                     |
| Affirmation Tested by :  Technical Manager<br>Name : Byeongil Jeong (Signature) Name : Donghoon Lee (Signature)                                                                                   |                |                                                                      |                                                                                     |
| The above test report is the accredited test results by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA.                                                                                                                                                            |                |                                                                      |                                                                                     |
| September. 30. 2022                                                                                                                                                                                                                                                                  |                |                                                                      |                                                                                     |
| KOLAS(Korea Laboratory Accreditation Scheme) Accreditation                                                                                                                                                                                                                           |                |                                                                      |                                                                                     |
| KOREA GAS SAGETY CORPORATION 한국가스안전공사<br>ENERGY SAFETY EMPIRICAL RESEARCH CENTER 에너지안전시험연구원                                                                                                                                                                                          |                |                                                                      |                                                                                     |
| If you need to verify authenticity test, please contact *82(33-834-2500)Quality Manager                                                                                                                                                                                              |                |                                                                      |                                                                                     |
| KGSE-TP-16-02(06)                                                                                                                                                                                                                                                                    |                |                                                                      |                                                                                     |

한국가스안전공사

### Test Results

|                                                                                                                                                                                                            |                                                |                                                                      |                                                                                       |             |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|----------------------------------------------------------------------|---------------------------------------------------------------------------------------|-------------|
| Korea Gas Safety Corporation<br>Energy Safety Empirical Research Center<br>160-51, Songhakjcheon-ro, Juchon-myeon, Yeongwol-gun,<br>Gangwon-do, Republic of Korea<br>Tel : 033-834-2500 Fax : 033-750-1946 |                                                | Certificate No. :<br>KGSE-인공-22-162<br>Page( 2 / 1 ) ( 2 / 2 ) Pages |  |             |
| <b>0 Test results</b>                                                                                                                                                                                      |                                                |                                                                      |                                                                                       |             |
| Number                                                                                                                                                                                                     | Test items                                     | Unit                                                                 | Result                                                                                | Notes       |
| 1                                                                                                                                                                                                          | Hydrogen gas pressure cycle test <sup>1)</sup> | Room test temperature                                                | Cycle                                                                                 | 100 000     |
|                                                                                                                                                                                                            |                                                | Minimum test temperature                                             | Cycle                                                                                 | 1 000       |
|                                                                                                                                                                                                            |                                                | Maximum test temperature                                             | Cycle                                                                                 | 1 000       |
| 2                                                                                                                                                                                                          | External leakage test <sup>2)</sup>            | High pressure                                                        | —                                                                                     | Bubble-free |
| 3                                                                                                                                                                                                          | Internal leakage test <sup>3)</sup>            | Low pressure                                                         | —                                                                                     | Bubble-free |
|                                                                                                                                                                                                            |                                                | Worst case fault pressure test <sup>4)</sup>                         | Cycle                                                                                 | 10          |
| 4                                                                                                                                                                                                          | Leakage                                        | External leakage test <sup>5)</sup>                                  | —                                                                                     | Bubble-free |
|                                                                                                                                                                                                            |                                                | Internal leakage test <sup>6)</sup>                                  | —                                                                                     | Bubble-free |
| 5                                                                                                                                                                                                          | Proof pressure test <sup>7)</sup>              | Low pressure                                                         | —                                                                                     | No leakage  |
| 6                                                                                                                                                                                                          | Hydrostatic strength test <sup>8)</sup>        | —                                                                    | —                                                                                     | No leakage  |

1) Hydrogen gas pressure cycle test : 100 000 cycles shall be completed at room temperature, with additional 1 000 cycles at an ambient temperature of -40 °C (+3 °C, -3 °C) and 1 000 cycles at an ambient temperature of 85 °C (+3 °C, -3 °C).  
- Pressure : Less than 5 % of the component pressure rating and the component pressure rating (+3 %, -0 %)  
2) External leakage test :  
- Pressure : At least 100 % of the component pressure rating  
- Temperature : -40 °C (+3 °C, -3 °C) and 85 °C (+3 °C, -3 °C)  
3) Internal leakage test :  
- Pressure : The pressure for the high pressure test is at least 100 % of the component pressure rating, and the pressure for the low pressure test is 25 % or less of the component pressure rating.  
- Temperature : -40 °C (+3 °C, -3 °C) and 85 °C (+3 °C, -3 °C)  
4) Worst case fault pressure test : Cycling is completed between 5 % or less of 110 % of the component pressure rating and at least 110 % of the component pressure rating (+3 %, -0 %)  
5) Proof pressure test : The pressure is slowly increased to 150 % of the component pressure rating and maintain that pressure for 10 min  
6) Hydrostatic strength test : pressure is increased to 2.4 times of the component pressure rating  
- End -

KGSE-TP-16-02(06)

한국가스안전공사



# HIGH PRESSURE NEEDLE VALVE

Control and open/close the flow, Manual valve

## KOLAS CERTIFICATION

KOLAS Hydrogen charging station valve certificate

| Test Report                                                                                                                                                                                                                                                                  |                |                                                                |            |                                      |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------|----------------------------------------------------------------|------------|--------------------------------------|
| Korea Gas Safety Corporation<br>Energy Safety Empirical Research Center<br>1467-51, Songhakjucheon-ro, Jucheon-myeon, Yeongwol-gun,<br>Gangwon-do, Republic of Korea<br>Tel : 033-834-2500 Fax : 033-750-1946                                                                |                | Certificate No. :<br>KGSE-TP-16-02-163<br>Page( 1 )/( 2 )Pages |            |                                      |
| <b>1. Client</b><br>○ Name : Hiflux Corporation<br>○ Address : 361-23, Gapcheon-ro, Yuseong-gu, Daejeon, Republic of Korea                                                                                                                                                   |                |                                                                |            |                                      |
| <b>2. Test sample/Product name :</b>                                                                                                                                                                                                                                         |                |                                                                |            |                                      |
| Type                                                                                                                                                                                                                                                                         | Model No.      | Size                                                           | Sample No. | Hydrogen service level <sup>1)</sup> |
| Manual Valve                                                                                                                                                                                                                                                                 | HRS-NV20VSI2-S | 19.05 mm <sup>1)</sup>                                         | #3         | 1170                                 |
| 1) 3/4 inch is equivalent to 19.05 mm<br>2) Maximum allowable working pressure specified by manufacture : 96.3 MPa                                                                                                                                                           |                |                                                                |            |                                      |
| 3. Test period : 2022.01.24. ~ 2022.04.26.                                                                                                                                                                                                                                   |                |                                                                |            |                                      |
| 4. Location of Test : ■ Permanent Test Lab □ On Site Testing<br>(Address : 1467-51, Songhakjucheon-ro, Jucheon-myeon, Yeongwol-gun,<br>Gangwon-do, Republic of Korea)                                                                                                        |                |                                                                |            |                                      |
| 5. Test method used : KS B ISO 9880-3 : 2018<br>10.2.2 Hydrogen gas pressure cycle test, 10.2.3 External leakage test,<br>10.2.4 Internal leakage test, 10.2.5 Worst case fault pressure test,<br>10.2.6 Proof pressure test, 10.2.7 Hydrostatic strength test               |                |                                                                |            |                                      |
| 6. Test Results : (See attached sheets)<br>This test report is specific to a sample item provided by client<br>* marked test result is beyond the range of the accreditation of testing institution<br>Related to KS Q ISO/IEC 17025 and KOLAS Accreditation simultaneously. |                |                                                                |            |                                      |
| Affirmation Tested by : [Signature] Technical Manager : [Signature]<br>Name : Byeongil Jeong Name : Donghoon Lee                                                                                                                                                             |                |                                                                |            |                                      |
| The above test report is the accredited test results by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA.                                                                                                                                                    |                |                                                                |            |                                      |
| September. 30. 2022                                                                                                                                                                                                                                                          |                |                                                                |            |                                      |
| KOLAS(Korea Laboratory Accreditation Scheme) Accreditation                                                                                                                                                                                                                   |                |                                                                |            |                                      |
| KOREA GAS SAFETY CORPORATION 한국가스안전공사<br>ENERGY SAFETY EMPIRICAL RESEARCH CENTER 에너지안전연구소                                                                                                                                                                                    |                |                                                                |            |                                      |
| If you need to verify authenticity test, please contact +82(33)834-2500(Quality Manager)                                                                                                                                                                                     |                |                                                                |            |                                      |
| KGSE-TP-16-02(06)                                                                                                                                                                                                                                                            |                |                                                                |            |                                      |

| Test Results                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                                                |                                                                                                                                                          |                           |                                                                        |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|------------------------------------------------------------------------|
| Korea Gas Safety Corporation<br>Energy Safety Empirical Research Center<br>1467-51, Songhakjucheon-ro, Jucheon-myeon, Yeongwol-gun,<br>Gangwon-do, Republic of Korea<br>Tel : 033-834-2500 Fax : 033-750-1946                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                                                | Certificate No. :<br>KGSE-TP-16-02-163<br>Page( 2 )/( 2 )Pages                                                                                           |                           |                                                                        |
| o Test results                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |                                                |                                                                                                                                                          |                           |                                                                        |
| Number                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | Test items                                     | Unit                                                                                                                                                     | Result                    | Notes                                                                  |
| 1                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | Hydrogen gas pressure cycle test <sup>1)</sup> | Room test temperature : Cycle<br>Minimum test temperature : Cycle<br>Maximum test temperature : Cycle                                                    | 100 000<br>1 000<br>1 000 |                                                                        |
| 2                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | External leakage test <sup>2)</sup>            | High pressure :<br>Low pressure :<br>Worst case fault pressure test <sup>3)</sup>                                                                        | —<br>—<br>Cycle           | Bubble-free<br>Bubble-free<br>10                                       |
| 4                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | Leakage test <sup>4)</sup>                     | External leakage test <sup>5)</sup> :<br>Internal leakage test <sup>6)</sup> :<br>Low pressure :<br>High pressure :<br>Proof pressure test <sup>7)</sup> | —<br>—<br>—<br>—<br>—     | Bubble-free<br>Bubble-free<br>Bubble-free<br>Bubble-free<br>No leakage |
| 6                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | Hydrostatic strength test <sup>8)</sup>        |                                                                                                                                                          | —                         | No leakage                                                             |
| 1) Hydrogen gas pressure cycle test : 100 000 cycles shall be completed at room temperature, with additional 1 000 cycles at an ambient temperature of -20 °C (+3 °C, -3 °C) and 1 000 cycles at an ambient temperature of 85 °C (+3 °C, -3 °C)<br>- Pressure : Less than 5 % of the component pressure rating and the component pressure rating (+3 %, -3 %)<br>2) External leakage test<br>- Pressure : At least 100 % of the component pressure rating<br>- Temperature : -40 °C (+3 °C, -3 °C) and 85 °C (+3 °C, -3 °C)<br>3) Internal leakage test<br>- Pressure : The pressure for the high pressure test is at least 100 % of the component pressure rating, and the pressure for the low pressure test is 2.5 % or less of the component pressure rating<br>- Temperature : -40 °C (+3 °C, -3 °C) and 85 °C (+3 °C, -3 °C)<br>4) Worst case fault pressure cycle test : Cycling is completed between 5 % or less of 110 % of the component pressure rating and at least 110 % of the component pressure rating (+3 %, -3 %)<br>5) Proof pressure test : The pressure is slowly increased to 150 % of the component pressure rating and maintain that pressure for 10 min<br>6) Hydrostatic strength test : pressure is increased to 2.4 times of the component pressure rating<br>- End - |                                                |                                                                                                                                                          |                           |                                                                        |
| KGSE-TP-16-02(06)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |                                                |                                                                                                                                                          |                           |                                                                        |



**ECO-FRIENDLY  
GREEN MARKETING**

The living spaces are safe with  
eco-friendly, individual systems

**HIFLUX Co., LTD**

**Address.** 361-23, Gapcheon-ro, Yuseong-gu, Daejeon, 34037, Republic of Korea

**Tel.** +82-42-933-5670 **Home.** [www.hiflux.com](http://www.hiflux.com)